

**To: All Vendors Bidding on The College of New Jersey
Eickhoff Hall Chiller Replacement**

**From: Roselle Horodeski
Finance & Business Services**

Date: January 5, 2012

ADDENDUM NO. 1

ISSUE DATE: January 5, 2012

REFERENCE: The College of New Jersey
Eickhoff Hall Chiller Replacement
AB120022

Date of Original Bidding Documents: December 11, 2011

INTENT: This Addendum forms a part of the Contract Documents and modifies the original Bidding Documents and Prior Addenda, if any, as identified above. Acknowledge receipt of this Addendum in the space provided on the Bid Form. Failure to do so may subject Bidder to disqualification.

CONTRACTOR QUESTIONS:

Question 1: Can the crane be driven on the sidewalks?

Response: Cranes are not allowed on the front of Eickhoff Hall in the area of the Alumni Grove. Cranes are allowed on the walkway between Packer Hall and Eickhoff Hall (Fire Lane). If this crane location is taken, the work must be expedited early in the morning in order to keep the fire lane open. Another location for placement of the crane is the asphalt parking area near the loading dock at Eickhoff Hall.

Question 2: Does the lightning protection need to be re-certified.

Response: The lightning rods need to be hooked back up. They do not need to be re-certified.

Attachment: Pre-bid sign-in sheet

END OF ADDENDUM NO. 1

